



Nga KSHE, Kablli i furnizimit PPY-5x16 mm<sup>2</sup>

Nga UPS, Kablli i furnizimit PPY-5x4 mm<sup>2</sup>



Qarku	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29		30	31	32	33	33	
Fuqja e instaluar (kW)	0.9	0.9	0.6	0.6	1.2	0.6	0.6	0.6	0.6	0.6	0.6	1.2	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.16	0.6	0.2	0.02	0.06	0.01	0.01		0.3	0.3	0.3	3.0	6.0		
Shpërndarja e fazave	L1	L2	L3	L1	L2	L3	L1	L2	L3	L1	L2	L3	L1	L2	L3	L1	L2	L3	L1	L2	L3	L1	L2	L3	L1	L2	L3	L1	L2		L1	L2	L3	L1	L1, L2, L3	
Tipi i shpënziesit	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	Priza	dyshe me	Priza	dyshe me	Priza	dyshe me	Priza	dyshe me	Priza	dyshe me	Priza	dyshe me	Priza	dyshe me		Multi split	Njesia Kanalore	Multi split	Njesia Kanalore	Multi split	Njesia Kanalore
MAKINERIA - HVAC																																				

Qarku	1	2	3	4	5	6
Fuqja e instaluar (kW)	0.5	0.5	0.5	0.5	0.5	0.5
Shpërndarja e fazave	L1	L2	L3	L1	L2	L3
Tipi i shpërndarjes	Priza	Priza	Priza	Priza	Priza	Priza
Tipi i shpërndarjes	UPS	UPS	UPS	UPS	UPS	UPS

P<sub>inst</sub>= 25.36 [kW]  
I<sub>inst</sub>= 38.57 [A]  
K<sub>nj</sub>= 0.7  
P<sub>nj</sub>= 17.75 [kW]  
I<sub>nj</sub>= 27.00 [A]

P<sub>inst</sub>= 3.0 [kW]  
I<sub>inst</sub>= 1.97 [A]  
K<sub>nj</sub>= 0.7  
P<sub>nj</sub>= 2.1 [kW]  
I<sub>nj</sub>= 3.19 [A]

OBJEKTI:
PIKA INFORMUESE PËR TURIST
INVESTITORI / KLIJENTI:
SWISSCONTACT KOSOVO (SC) Promoting Private Sector Employment (PPSE) Project
ZYRA PROJEKTUESE:
LLUJTI I PROJEKTI: PROJEKT KRYEBOR ZBATUES
FAZA: ELEKTRIKA
APROVUAR NGA:
EMËRTIMI I FLETËS:
Skema njepolare elektrike
DATA: 06.02.2023 PËRPIJESIA: 1:50
FORMATI: DIN A3 NR. I PLANIT: 7